



— EST. 2007 —  
**APPROVED CODE**  
SERVICES

## **VI. Mechanical Plan Review - Required Information from PA L&I Form UCC2**

- Sheet # \_\_\_\_ N/A a. Show all required wall louvers, penetrations and fans.
- Sheet # \_\_\_\_ N/A b. Indicate roof-mounted equipment locations.
- Sheet # \_\_\_\_ N/A c. Show all mechanical equipment, piping, ductwork (above/below slab) on the mechanical floor and/or roof plan.
- Sheet # \_\_\_\_ N/A d. Provide mechanical plans for each floor and the roof. These shall show the ductwork layouts, schedules, notes, legends, piping schematics, and details necessary to define the system being installed.
- Sheet # \_\_\_\_ N/A e. Indicate air distribution devices and show cfm for all supply, return and exhaust devices.
- Sheet # \_\_\_\_ N/A f. Indicate the location of all equipment components required for a complete system.
- Sheet # \_\_\_\_ N/A g. Show the smoke ventilation of atriums and pressurization of high-rise stairwells.
- Sheet # \_\_\_\_ N/A h. Show condensation drains, primary and secondary, from the unit to the point of discharge.
- Sheet # \_\_\_\_ N/A i. Indicate toilet exhaust requirements.
- Sheet # \_\_\_\_ N/A j. Show mechanical room layouts at sufficient scale for dimensions and details to be ascertained.
- Sheet # \_\_\_\_ N/A k. Show the size of duct runs.
- Sheet # \_\_\_\_ N/A l. Indicate controls for fan shutdown: emergency manual and automatic smoke detection.
- Sheet # \_\_\_\_ N/A m. Show the location of all UL 555-certified fire dampers, ceiling radiation dampers, smoke dampers, and fire doors.
- Sheet # \_\_\_\_ N/A n. Show all fire-rated walls (both existing and new) with their ratings on the mechanical plans.
- Sheet # \_\_\_\_ N/A o. All penetrations of fire-rated construction must be per manufacturer's details.
- Sheet # \_\_\_\_ N/A p. Room names and numbers for each floor should be on a floor plan for each level.
- Sheet # \_\_\_\_ N/A q. Provide outside air ventilation rate per the International Mechanical Code.
- Sheet # \_\_\_\_ N/A s. Provide gas piping layout on the floor plan for each floor. If it is a multi-story building, all gas piping shall be shown per floor. Include pipe sizes, water column, and type of material. Provide a schedule of connected equipment, total BTUH demand, total equivalent length, and most remote gas appliance.